

राष्ट्रीय कोशिका विज्ञान केंद्र  
**NATIONAL CENTRE FOR CELL SCIENCE**  
 (An Autonomous Institution of the Department of Biotechnology, Govt. of India)  
 Savitribai Phule Pune University Campus, Ganeshkhind, Pune- 411007

**MINUTES OF PRE-BID MEETING FOR SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 380KVA DG SET AT JIDNYASA BLDG., KOTHRUD, PUNE**

**Tender Ref No. : NCCS/MAINT/DG/454E/2023; dt-01/11/2023.**  
**Date : 10/11/2023 @ 12 Hrs**  
**Venue : Board Room at 'A' Building, NCCS, Pune.**

Clarification of all the queries raised by prospective bidders during pre-bid is as listed below.

S.N.	Particular	Query	Clarification
1	Tech Bid, Sr. No. 3.2.(vii): Earnest Money Deposit (EMD)	MSME registered Bidders requested for exemption from submission of EMD.	NCCS not agreed for the same as there is no such provision in the guidelines.
2	Tech Bid, Annexure- IV, No. 10- Technical Specification Chart for product to be offered- AMF panel	Bidder requested to clarify wheather AMF Panel is in Scope of work or not?	NCCS clarified that AMF panel is in Electrical Panel vendor scope.
3	Installation of 380 KVA DG Set	Bidder asked that if 380 KVA DG. Set to be installed in place of existing Canteen Shed, NCCS has to remove the said Shed & to handover clean place to the contractor for Installation of 380 KVA D. G. Set.	NCCS agreed for the same.
4	Tech Bid, Point 2 Scope of work- Foundation and civil works	Bidder requested to provide RCC Drawing & approval from NCCS for civil foundation for DG Set.	NCCS informed that civil foundation is in DG vendor scope as per site condition. NCCS/ Consultant shall only review & approve.
5	Tech Bid, Point No. C. Alternator Brief Note	Bidder asked that in Technical Specification to providing Thermistor Winding for protection against overheating in alternator, you have mention that the winding temperature 3 nos of rotors should detect on DG Set control panel but there is no provision in DG Set control panel to detect winding temperature for that we have to provide 3 temperature detector, it will indicate on separate temperature scanner connecting with control cable in 3 Nos winding rotors, for that you have to do the separate provision in AMF Panel providing separate temperature scanner. Which will provide an additional charges basis if required.	NCCS informed that temperature scanner is not required. Contractor shall supply DG set as per technical specification mentioned in the tender document.

<b>S.N.</b>	<b>Particular</b>	<b>Query</b>	<b>Clarification</b>
6	Tech Bid, Point No. vi. ALTERNATOR	Bidder asked that in Technical Specification to providing PMG Alternator but the DG Set manufactures does not manufacture PMG OEM provide regular AREOP Alternator, which is equivalent to PMG both make have same advantage and same parameters, winding pitch of 2/3 3 no rotors winding and the voltage regulation of both are same but if NCCS want to go for PMG Alternator, NCCS will have to pay additional charge for the same.	NCCS informed that PMG is required. Contractor shall supply DG set as per technical specification mentioned in the tender document and anything extra shall be done as per quoted rates.
7	Additional quantity	Bidder asked that if any material & labour required extra beyond the specific BOQ Quantity during the installation work, the same will be supply / provide on Extra Basis after pre-approval of NCCS.	NCCS clarified that anything extra shall be done as per quoted rates only after approval from NCCS/ Consultant.
8	Pollution Control Board Approval	Bidder asked that 380 KVA D. G. Set is approved by ARAI as per CPCB -2 Norms. Hence, there is no need to obtain Separate Pollution Control Board Approval.	NCCS clarified that if local PCB approval is required, contractor's responsibility to carry out this work at his quoted rates. Nothing extra will be payable. NCCS will pay statutory charges only.
9	Price Bid, Sr. No. 1.1-SITC of DG set	Clarification from NCCS.	NCCS informed that consider M25 grade instead of M20 grade for CC foundation for DG set.
10	Due date for submission of Tender 21/11/2023 @15 Hrs	Bidder requested for extension for submission of tender till 24/11/2023 due to Diwali holidays.	NCCS agreed for the same and extended date upto 24/11/2023 @ 15 Hrs.