

राष्ट्रीय कोशिका विज्ञान केंद्र  
**NATIONAL CENTRE FOR CELL SCIENCE**  
 (An Autonomous Institution of the Department of Biotechnology, Govt. of India)  
 Savitribai Phule Pune University Campus, Ganeshkhind, Pune- 411007

**CORRIGENDUM TO THE MINUTES OF PRE-BID MEETING HELD ON 10/11/2023**

**FOR SITC, QUALIFICATION AND VALIDATION OF c-GMP COMPLIANT MAMMALIAN CELL LINE REPOSITORY ON TURNKEY BASIS AT NCCS JIDNYASA BUILDING, KOTHRUD, PUNE**

Tender Ref No. : NCCS/MAINT/GMP/454C/2023-24; dt-01/11/2023.

S.N.	PARTICULAR	QUERY	CLARIFICATION
1	Tech Bid, Air Handling Units- All Air Handling Unit (AHU) shall be Eurovent Certified EN-1886 & EN-130353 with following details	Clarification by NCCS	NCCS clarified that Eurovent certification for all AHU is not mandatory.
<b>C</b>	<b>DENSOL ENGINEERING PVT LTD</b>		
4	Tech Bid, Sr. No.3.2.2- Pre-qualification Criteria of Experience- The bidder should have satisfactory completed similar type of works for setting up of BSL-1/2 functional laboratories/facilities for Biologicals within last five years (upto last day of submission of tender). Similar type of works means complete turnkey project execution including but not limited to project management, designing, supplying, installing, commissioning, testing and validating Grade B, Grade C and Grade D Cleanrooms, allied utilities, and integration of all relevant services in a turnkey manner as per cGMP standards of Schedule M/ FDA-US/ EMA-EU/ WHO for BSL-2 biologicals laboratories / facilities. The lab should have been made fully functional.	Bidder requested if they can submit copy of work order/ agreement / completion certificate showing GLP.	** NCCS did not agreed for the same.
	<p>** In the Pre-bid Meeting held on 10/11/2023, the clarification given in respect of the 3.2.2. Prequalification Criteria under Sr. No. 4 that “<b>NCCS agreed for the same</b>”</p> <p>However, in the Minutes of the Meeting, inadvertently it was written as “<b>NCCS did not agreed for the same</b>” which is incorrect.</p>		